



Ref. Certif. No.

DE 2-029978

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Switched Mode Power Supply
Name and address of the applicant	Excelsys Technologies Ltd. 27 Eastgate Business Park Little Island, Co. Cork, Ireland
Name and address of the manufacturer	Excelsys Technologies Ltd. 27 Eastgate Business Park Little Island, Co. Cork, Ireland
Name and address of the factory	Shenzhen Watt Electronics Co., Ltd. 5 TUNNEL 1, TANGFANG GARDEN 35 DISTRICT BAO'AN, Shenzhen, 518133 Guangdong, P.R. China
Ratings and principal characteristics	Input: 120-200V, 50/60 Hz, 10-4.6A (1,3,5) or 4-2.3A (2,4,6) Out1: 24Vdc/42A (1); 24Vdc/21A (2); 48Vdc/42A (3); 48Vdc/10.5A (4); 36Vdc/28A (5); 36Vdc/14A (6) Out2: 12Vdc/0.3A (1-6)
Trademark (if any)	excelsys
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	Xa1000-24defgh (1); Xa500-24defgh (2); Xa1000-48defgh (3); Xa500-48defgh (4); Xa1000-36defgh (5); Xa500-36defgh (6) detail information for variables adefgh see test report
Additional information (if necessary may also be reported on page 2)	models differ in output voltage and output power
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2014 for national differences see test report
As shown in the Test Report Ref. No. which forms part of this Certificate	60391737 002

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland LGA Products GmbH
Tillystr. 2, 90431 Nürnberg, Germany
Phone + 49 221 806-1371
Fax + 49 221 806-3935
Mail: cert-validity@de.tuv.com
Web : www.tuv.com

Date: 2021-01-25

Signature:

Dipl.-Ing. V. Ebinghaus